



New-Indy Catawba LLC  
Catawba, South Carolina

**Public Notification of Downtime Activity: COMPLETE**  
**May 28, 2023**

In accordance with Paragraph 1 of Appendix “A” of the US Environmental Protection Agency (“EPA”) Consent Decree dated November 16, 2022 (Civil No. 0:21-cv-02053-SAL), and New-Indy Catawba LLC’s (“New-Indy”) Public Notification Plan dated May 17, 2021, New-Indy presents the following Public Notification.

**Description of Activity:**

The steam stripper was offline for unplanned issues.

PLANNED

UNPLANNED

**Purpose of Activity:**

This event was a result of a process controls communication module error, and included two very short and separate events. The malfunction has been corrected. During this unplanned downtime event, there was no reportable flow of foul condensate through the hard pipe to the ASB.

**Activity Status:**

Event 1	<i>May 27, 2023 (21:25 to 21:45), 20 minutes duration</i>		
Event 2	<i>May 28, 2023 (13:55 to 14:15), 20 minutes duration</i>		
ORP Monitoring & Controls	<i>Functioning</i> <input checked="" type="checkbox"/>	<i>Excursions: No</i> <input checked="" type="checkbox"/> <i>Yes</i> <input type="checkbox"/>	<i>N/A</i>
Current Status	<i>Work is Complete</i> <input checked="" type="checkbox"/>		<i>Stripper is Online</i> <input checked="" type="checkbox"/>

**Contact Information:**

New-Indy may be reached at [catawbainfo@new-indy.com](mailto:catawbainfo@new-indy.com) concerning this activity.