



New-Indy Catawba LLC
Catawba, South Carolina

Public Notification of Downtime Activity: COMPLETE
July 4, 2023

In accordance with Paragraph 1 of Appendix “A” of the US Environmental Protection Agency (“EPA”) Consent Decree dated November 16, 2022 (Civil No. 0:21-cv-02053-SAL), and New-Indy Catawba LLC’s (“New-Indy”) Public Notification Plan dated May 17, 2021, New-Indy presents the following Public Notification.

Description of Activity:

The steam stripper was offline for unplanned issues.

PLANNED

UNPLANNED

Purpose of Activity:

Moisture in electronics interrupted operation of the stripper feed pump. Following trouble shooting and repairs to the electronics controlling operation of the stripper feed it was immediately returned to service. During this event, ORP controls of foul condensate flows through the hardpipe to the ASB were maintained with no excursions.

Activity Status:

Event 1	<i>July 4, 2023 4:26 pm to July 5, 2023 2:01 am, 575 minutes duration</i>		
ORP Monitoring & Controls	<i>Functioning</i> <input checked="" type="checkbox"/>	<i>Excursions: No</i> <input checked="" type="checkbox"/> <i>Yes</i> <input type="checkbox"/>	<i>N/A</i>
Current Status	<i>Work is Complete</i> <input checked="" type="checkbox"/>		<i>Stripper is Online</i> <input checked="" type="checkbox"/>

Contact Information:

New-Indy may be reached at catawbainfo@new-indy.com concerning this activity.