



New-Indy Catawba LLC  
Catawba, South Carolina

**Public Notification of Downtime Activity: COMPLETE**  
**July 16, 2023**

In accordance with Paragraph 1 of Appendix “A” of the US Environmental Protection Agency (“EPA”) Consent Decree dated November 16, 2022 (Civil No. 0:21-cv-02053-SAL), and New-Indy Catawba LLC’s (“New-Indy”) Public Notification Plan dated May 17, 2021, New-Indy presents the following Public Notification.

**Description of Activity:**

The steam stripper was offline for unplanned issues.

PLANNED

UNPLANNED

**Purpose of Activity:**

A turbine generator trip unbalanced mill steam loads causing the stripper to go offline due to lack of steam. The turbine generator was restarted and once operations returned to normal the stripper was brought back online. During this event, ORP controls of foul condensate flows through the hardpipe to the ASB were maintained with no excursions.

**Activity Status:**

Event 1	<i>July 16, 2023 at 4:44 pm to 4:53 pm, 9 minutes duration</i>		
ORP Monitoring & Controls	<i>Functioning</i> <input checked="" type="checkbox"/>	<i>Excursions: No</i> <input checked="" type="checkbox"/> <i>Yes</i> <input type="checkbox"/>	<i>N/A</i>
Current Status	<i>Work is Complete</i> <input checked="" type="checkbox"/>		<i>Stripper is Online</i> <input checked="" type="checkbox"/>

**Contact Information:**

New-Indy may be reached at [catawbainfo@new-indy.com](mailto:catawbainfo@new-indy.com) concerning this activity.